



Product Service

CERTIFICATE

No. Z2 112447 0001 Rev. 00

Holder of Certificate: **Tenka Solar GmbH**

Linprunstr. 49
80335 München
GERMANY

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Poly-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262107402-00

Valid until: 2025-04-14

Date, 2021-05-14

(Zhulin Zhang)



Product Service

CERTIFICATE

No. Z2 112447 0001 Rev. 00

Model(s):

TKA-XXXP-72, xxx= 330 to 360 in step of 5
TKA-XXXP-60, xxx= 275 to 300 in step of 5
TKA-XXXP-54, xxx= 245 to 270 in step of 5
TKA-XXXP-48, xxx= 220 to 240 in step of 5
TKA-XXXP-24, xxx= 110 to 120 in step of 5
TKA-XXXP-144, xxx = 335 to 375 W in step of 5
TKA-XXXP-120, xxx = 280 to 310 W in step of 5
TKA-XXXP-108, xxx = 255 to 280 W in step of 5
TKA-XXXP-96, xxx = 225 to 250 W in step of 5
xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790.

Tested according to:

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016